



FEATURES & BENEFITS

- Sprinkler System (Optional Dirty Air System)
- Factory installed internal sprinkler system includes all internal piping, terminating to an external coupling. Piping and connections to an external water supply by others.
- Per NFPA 13, the water pressure should be able to provide the design flow of 0.2 gpm/ft² of horizontal area. A minimum recommended operating pressure of 10 psi will achieve the required flow. Make sure the water supply can handle the flow of 25 gpm per head at 10 psi.

CAUTION

Check to see if local fire codes require higher pressures.